



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@po.state.ct.us

www.ct.gov/csc

March 30, 2006

Daniel A. Weekley
Director Northeast Government Affairs
Dominion Resources Services, Inc.
Rope Ferry Road (Route 156)
Waterford, CT 06385

RE: **DOCKET NO. F-2006** – Connecticut Siting Council Review of the Ten-Year Forecast of Connecticut Electric Loads and Resources

Dear Mr. Weekley:

Don

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than April 20, 2006. To help expedite the Council's review, please file individual responses as soon as they are available.

Please forward an original and 20 copies to this office. In accordance with the State Solid Waste Management Plan, the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. A list of parties and intervenors is enclosed. Fewer copies of bulk material may be provided as appropriate.

Yours very truly,

S. Derek Phelps
Executive Director

SDP/MP

c: Council Members
Parties and Intervenors
Lillian M. Cuoco, Esq., Senior Counsel, Dominion Resources Services Inc.
Kenneth C. Baldwin, Esq., Robinson & Cole LLP

Docket F-2006
Dominion Pre-Hearing Interrogatories, Set One

1. Listed below are the data from the March 2006 ISO-New England Seasonal Claimed Capability Report (rounded to two decimal places). Does Dominion Nuclear Connecticut, Inc. (Dominion) agree with the numbers listed below? If no, provide the most up to date data.

Net Capability - MW	Summer	Winter
Millstone Point 2	882.14	881.96
Millstone Point 3	1155.00	1155.48

2. How does Dominion compute seasonal claimed capability?
3. Provide the status of the license renewal process for both Unit 2 and Unit 3.
4. Are the upgrades to the low pressure turbine rotors complete for Unit 2 and Unit 3?
5. Review the 2005 report titled *Connecticut Siting Council Review of the Forecast of Connecticut Electric Loads and Resources*, and provide any comments that may be helpful in the preparation of the 2006 report. For example, are there any new topics that Dominion believes should be addressed in the 2006 report that were not covered in the 2005 report?